

MU2R17

COOLING															
OPERATION	COMBINATION OF INDOOR UNIT (kBtu/h CLASS)						TOTAL CAPACITY						INPUT(W)		
							MIN.		RATED		MAX.				
	UNIT-A	UNIT-B	UNIT-C	UNIT-D	UNIT-E	TOTAL	Btu/h	kW	Btu/h	kW	Btu/h	kW	MIN.	RATED	MAX.
1 UNIT	5	-	-	-	-	5	3,000	0.88	5,000	1.47	5,750	1.69	226	381	477
	7	-	-	-	-	7	4,200	1.23	7,000	2.05	8,050	2.36	303	540	683
	9	-	-	-	-	9	5,400	1.58	9,000	2.64	10,350	3.03	408	676	864
	12	-	-	-	-	12	7,200	2.11	12,000	3.52	13,800	4.04	540	926	1,176
	15	-	-	-	-	15	8,520	2.50	14,200	4.16	16,330	4.79	648	1,196	1,588
2 UNIT	5	5	-	-	-	10	6,000	1.76	10,000	2.93	11,500	3.37	414	682	889
	5	7	-	-	-	12	7,200	2.11	12,000	3.52	13,800	4.04	486	833	1,058
	5	9	-	-	-	14	8,400	2.46	14,000	4.10	16,100	4.72	583	988	1,376
	7	7	-	-	-	14	8,400	2.46	14,000	4.10	16,100	4.72	583	988	1,376
	7	9	-	-	-	16	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	5	12	-	-	-	17	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	9	9	-	-	-	18	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	7	12	-	-	-	19	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	5	15	-	-	-	20	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	9	12	-	-	-	21	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	7	15	-	-	-	22	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	9	15	-	-	-	24	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699
	12	12	-	-	-	24	9,600	2.81	16,000	4.69	18,400	5.39	657	1,251	1,699